


# Trade Data

# OUH

Oil Unit Heaters

OUH F Axial Fan / OUH C Centrifugal Fan

Heat Outputs from 20kW - 60kW



**powrmatic**



Authorised User No. 00175

# Product Overview

## Benefits

### Installer Friendly

- Compact
- Stainless steel combustion chamber/heat exchanger as standard
- Riello Burners
- 35 and 28 second fuel oil options
- Axial fan versions for freeblowing applications
- Centrifugal fan option for ducted applications

### Caring For The Environment

- High Efficiency
- ECA Approved Models
- Biofuel Options

### Peace Of Mind

- More Than Fifty Years Experience In Warm Air
- Two Year Parts And One Year Labour Guarantee
- Ten Year Combustion Chamber/Heat Exchanger Warranty

**Configuration** Powrmatic OUH oil fired unit heaters can be supplied in axial fan freeblowing format, to be installed directly into the space to be heated, or with centrifugal fan for ducted applications. Heaters are generally arranged for on/off operation however they may also be specified with high/low heat output.

**Efficiencies** Fuel usage and emissions are a key consideration. Additionally, all heaters have efficiencies which meet or exceed the requirements of both current Building Regulations and the United Kingdom Enhanced Capital Allowance scheme.

**Cabinet** Of unitary construction and finished with hardwearing epoxy powder coat stove baked paint.

**Combustion Chamber/Heat Exchanger** Manufactured from 304 grade stainless steel and life cycle tested to ensure long service life.

**Burners** Powrmatic ouh heaters are specification matched to Riello pressure jet oil burners. Heaters are arranged, as standard, for operation on Class D light distillate 35 second gas oil.

Alternative kerosene (28 sec) or liquid biofuel firing available to order.

All ouh heaters have the benefit of fire safety valve and oil filter (supplied loose).

**Air Movement** Freeblowing models are fitted with axial fan sets and discharge warmed air directly into the heated space via adjustable louvred horizontal grilles. Centrifugal fan models are fitted with a centrifugal fan close-coupled directly to the heater casing.

**Controls** Heaters, as standard, are provided with high temperature limit protection as well as connections for both heat and, where applicable, fan only operation.

Heaters may be connected to our compatible environmental control stations which are themselves available in two options.

The Powtrol control station provides a digital timeswitch with mechanical day and frost protection thermostats and switching options to enable 'fan only' operation for summer air movement.

Alternatively heaters may be specified with a tamperproof digital control that features optimised start and stop (mandatory for ECA , high/low and modulating applications) which includes a digital time switch, electronic day thermostat and frost protection thermostat. Remote temperature sensor option available.

Interconnecting wiring for all controls is the responsibility of the installer.

All heaters have the ability to provide 'fan only' summer air movement.

## OUH F / OUH C

Model			20	30	45	60	
<b>Output</b>		kW	20	30	45	60	
<b>Airflow</b>	Volume		m <sup>3</sup> /s	0.58	0.68	1.08	1.41
	Throw	OUH F	m	16	14	22	29
	Fan Static	OUH C	Pa	150	187	100	50
<b>Electrics</b>	Supply	Standard	V/Ph/Hz	230/1/50			
		Optional	V/Ph/Hz	400/3/50			
	OUH F	Motor	kW	0.10	0.10	0.37	0.37
		Start	amp	1.45	1.50	6.10	6.00
		Run	amp	0.82	0.86	2.00	2.60
	OUH C	Motor	kW	0.34	0.75	0.75	0.75
		Start	amp	3.75	15.00	15.00	15.00
		Run	amp	2.60	7.00	7.00	7.00
	<b>Fuel Oil</b>	Connection	BSP/Rc	1/4			
Consumption		l/h	2.27	3.41	5.19	7.00	
<b>Mounting Height</b>	OUHC	Min	m	2.50		3.00	
		Max	m	3.00		5.00	
<b>Overall Dimensions</b>	Height		mm	820	1102	1102	1102
	Width		mm	555	780	780	780
	Depth	ouhf	mm	745	1030	1030	1030
		ouhc	mm	1085	1468	1468	1468
<b>Installation Clearances</b>	Top		mm	1000	1000	1000	1000
	Side		mm	500	500	500	500
	Rear		mm	1000	1000	1000	1000
<b>Flue Diameter</b>			mm ø	100	125		
<b>Combustion Air Spigot</b>			mm ø	125			
<b>Noise Level - OUH F Models</b>			dBA	42	50	48	49
<b>Nett Weight</b>	OUH F		kg	62	126	126	126
	OUH C		kg	69	142	142	142

### Notes -

Fuel consumption and output figures based upon gross calorific values as -

Class D light distillate fuel oil gross CV 38.67 MJ/l (Nett 36.28 MJ/l)

Heaters have efficiency levels which meet with the minimum efficiency requirements of UK Part L2B Building Regulations

Heaters have efficiency levels which meet the criteria of the Enhanced Capital Allowance Scheme

Air handling data is assessed at room ambient conditions

Throw figures provide the distance to the point where the terminal velocity degrades to 0.25 m/s

Noise levels refer to OUH F axial fan models and measured 5m from appliance and in free field conditions


Motor kW, run and start amps apply to standard electrical supply as stated. For optional data contact sales

Combustion air spigot is an optional extra

Installer guidance notes on rear page


# Dimensions

## OUH F 20 Axial Fan




	A	B	C	D	E	F	G	H	J	K	M
<b>OUH F 20</b>	668	555	610	100	465	101	549	410	340	85	270

## OUH F 30 / 45 / 60 Axial Fan




	A	B	C	D	E	F	G	H	J	K	M
<b>OUH F 30</b>	975	780	847	125	490	276	490	636	418	165	270
<b>OUH F 45</b>	975	780	847	125	490	276	490	636	418	165	270
<b>OUH F 60</b>	975	780	847	125	490	276	490	636	418	165	270

## OUH C 20 Centrifugal Fan



	A	B	C	D	E	F	G	H	J	L	M
<b>OUH C 20</b>	668	555	610	100	465	101	549	410	340	370	270

## OUH C 30 / 45 / 60 Centrifugal Fan



	A	B	C	D	E	F	G	H	J	L	M
<b>OUH C 30</b>	975	780	847	125	490	276	490	636	418	494	270
<b>OUH C 45</b>	975	780	847	125	490	276	490	636	418	494	270
<b>OUH C 60</b>	975	780	847	125	490	276	490	636	418	494	270

# Installer Guide

**General** The following notes are provided as a help, however installers and operators should fully acquaint themselves with the more detailed guidance provided in the relevant installation manual. For copies of such manuals please consult our technical department or visit our website - [www.powrmatic.co.uk](http://www.powrmatic.co.uk)

**Standards** All Powrmatic OUH heaters must be installed, commissioned and operated with due regard to appropriate regulations, relevant Codes of Practice, the possible requirements of Local Authorities, Fire Officers and insurers as well as Powrmatic's installation manual.

**Position & Location** Powrmatic OUH heaters can be 'drop rod' suspended via purpose designed M10 suspension fixing points, attached to our optional wall support brackets or positioned on a level non-combustible base. In all cases it is important that all supporting structures have due regard to the relevant weight loadings.

Consideration should also be given to flue routes and points of exit, oil, electrical and control connections, the throw characteristics of the heater, issues of public access and the siting of environmental control stations and/or remote temperature sensors where the position needs to be representative of the zone temperature to which they refer.

Heaters should not be installed in hazardous areas or areas where there is a foreseeable risk of flammable or corrosion inducing particles, gases or vapours being drawn into the combustion air or main fan circuits.

Areas where special consideration or advice may be required could include but is not limited to -

- where de-greasing solvents are present, even in minute concentrations
- where paint spraying is carried out
- where styrenes or other laminating products are used
- where airborne silicone is present
- where petrol engined vehicles are stored or maintained
- where dust is present (ie wood working or joinery shops)
- where high levels of extract persist

Installation in such areas may be possible under specific conditions. Please consult our technical department for further information.



Hort Bridge  
Ilminster  
Somerset  
TA19 9PS

United Kingdom

Tel: +44 (0)1460 53535

Fax: +44 (0)1460 52341

Email [info@powrmatic.co.uk](mailto:info@powrmatic.co.uk)

[www.powrmatic.co.uk](http://www.powrmatic.co.uk)

**Plant Room or Enclosure Locations** It is possible to install centrifugal fan variants of the ouh heater within plant rooms or enclosures however specific requirements may need to be applied. Such requirements cover the provision of positive ductwork connections as well as ventilation for combustion air and general plant room or enclosure ventilation. It is recommended that you consult with our technical department or the installation manual prior to installation.

**Combustion Air & General Ventilation** Within the United Kingdom mandatory regulations may apply concerning the provision of combustion air and general heater ventilation.

If the heater is installed directly within the heated space and where that heated space has a natural ventilation rate greater than 0.5 air changes per hour then combustion air and general heater ventilation is probably not required. If the heated space has a natural ventilation rate of less than 0.5 air changes per hour then either natural ventilator openings or mechanical ventilation will be required. Please consult the installation manual for further details.

**Installation Clearances** Particular clearances may be necessary for the correct and safe function of the heater as well as for maintenance purposes. Such clearances are confirmed in the relevant installation manual.

**Flue** Each heater requires a separate flue system of the appropriate size. The flue should essentially be installed in the vertical plane and the number of bends kept to a minimum. The flue must be adequately supported and terminated with a suitable cowl, with due regard to the point of exit and it's proximity to any windows, doors or ventilation intakes etc.

**Pipework** Care should be taken when sizing pipework to ensure that maximum oil inlet pressures are not compromised under dynamic load conditions. Isolating valves and service unions should be provided for each heater and pipework installed with due regard for relevant standards and Codes of Practice.

## Guarantee

Powrmatic heaters are provided with a comprehensive guarantee covering both the heater and the heat exchanger. For United Kingdom sales the heater has the benefit of a two year parts and one year labour guarantee whilst the heat exchanger assembly has a **ten year** time related warranty. All guarantees are subject to terms and conditions.



Powrmatic pursues a policy of continuous improvement in both design and performance of its products and therefore reserves the right to change, amend or vary specifications without notice. Whilst the details contained herein are believed to be correct they do not form the basis of any contract and interested parties should contact the Company to confirm whether any material alterations have been made since publication of this brochure.

