


* A System with automatic by-pass valve is required *

Wiring diagram for use with an Alpha CD13R, CD18R & CD24R with a plug In Alpha 7-day digital 2 channel heating clock + Honeywell Y plan.





NOTE: Pump live must always be connected to the pump live terminal provided in the boiler control panel, e.g via junction box terminal 9



NOTE: To connect external control, remove link from terminals 1 and 2 and connect a 230/240v switched live to terminal 1

NOTE: If you would like the option of the 2 channel Easy Stat. Please place a link between 4 and 5 on the wiring center and omit the room thermostat

