

841 & 842

Seven Day Pulsed Output Electronic Timeswitches 110 Volt

INSTALLATION INSTRUCTIONS


The Model 841 & 842 Timeswitches must be installed by a competent electrician and the installation should conform to IEE Wiring Regulations.

Installation & Wiring

- Slacken the four fixing screws, one in each corner of the unit, and carefully separate the front and rear portions. Unplug the ribbon cable from the rear portion.
CAUTION: Do not allow either half of the unit to hang by the ribbon cable as damage could be caused.
- Remove the polystyrene packing piece from the top of the transformer. It is marked 'REMOVE'.
- Select the desired fixing position and observe the label 'THIS WAY UP' inside the rear portion. The two halves will only assemble correctly one way round.
- Four fixing holes are provided for attaching the rear portion to the wall or mounting surface.


Conduit box adaptors as shown below are available if required.

Part No.: 8/3223 Double Gang Surface Box Adaptor




- Surface cable entries to the units can be made from above, below or from the left hand side. Conduit or recessed cable entry is through the aperture in the rear moulding.
- For surface cable entry remove the appropriate knock-out and ensure one of the two cable clamps is positioned correctly.
- Connections to the units should be made as shown below.

MODEL 841



MODEL 842



If the control circuit(s) are to operate at 110V then terminals L & 1 (Model 841) and terminals L, 1 and 4 (Model 842) must be linked, ensuring that the cable is sheathed and of a size to carry the required load current.

If, however, the control circuit(s) are operating at other than 110V then no link(s) shall be fitted and in the case of Model 841 both terminals 1 and 2 should be connected to the load.

In the case of Model 842 terminals 1, 2 and 3 (if required) should be connected to the load controlled by Channel 1 and terminals 4, 5 and 6 (if required) to the load controlled by Channel 2.

- The unit is supplied set for a 5 second single pulse output. If a multi pulse output is required, proceed as described in paragraph 10 (b). If a number of pulses or the pulse duration is required to be different from supplied, proceed as described in paragraph 11(b).
- Upon completion of wiring plug in the ribbon cable ensuring the polarised plug is fully inserted into the socket. Refit the front half of the timeswitch ensuring correct alignment and that no cables are trapped before re-tightening the screws.

10. TO CHANGE FROM SINGLE TO MULTI PULSE OUTPUT

(a) Remove the front portion of the unit as described in 'Installation and Wiring' paragraph 1.

(b) A push/pull switch is provided on the rear of the printed circuit board inside the front portion of the unit.

With the switch pulled out (as supplied) this provides a single pulse output. Push the switch in to achieve a multi pulse output (½ second on followed by ½ second off).

On Model 842 a push/pull switch is provided for each channel to enable different types of pulsed output if required. The switch relating to each channel is clearly marked.

11. RESETTING OF SWITCHING DURATION

(a) Remove the front portion of the unit as described in 'Installation and Wiring' paragraph 1.

(b) The bank of four miniature rocker switches is mounted on the printed circuit board inside the front portion of the unit.

When switch no. 1 is 'on' 1 second duration is set.
 When switch no. 2 is 'on' 2 seconds duration is set.
 When switch no. 3 is 'on' 4 seconds duration is set.
 When switch no. 4 is 'on' 8 seconds duration is set.
 When all 4 switches are 'on' the duration is
 $1 + 2 + 4 + 8 = 15$ seconds.

Any combination of the 4 switches may be selected to set from 1 to 15 seconds in increments of 1 second.


If all 4 switches were 'off' there would be no output and so this setting should be avoided.

EXAMPLES


Slider Switch Positions	'ON' Duration	Slider Switch Positions	'ON' Duration
	NONE Do Not Use		8 seconds
	1 second		9 seconds
	2 seconds		10 seconds
	3 seconds		11 seconds
	4 seconds		12 seconds
	5 seconds (As supplied)		13 seconds
	6 seconds		14 seconds
	7 seconds		15 seconds

Technical Specification	Model 841	Model 842
Max. current rating of output	15A at 110 Vac	3A* (at 110 Vac on each channel. * If set as multi pulse output giving 15 pulses per event 200 times per week, rating reduces to 1A at 110 Vac Conversely if set as single pulse at 100 events per week, rating increases to 5A at 110 Vac
Output contacts	Enclosed single pole single throw (SPST) Type B	Enclosed single pole double throw (SPDT) voltage free on each channel Type B
Mains supply required	110 V (+/-10%) AC 50/60 Hz	100V (+/-10%) AC 50/60 Hz
Battery reserve	Retains memory settings for a period of 3 months during mains power failure (once battery is fully charged)	
Temperature Rating	0°C to 45°C	
Enclosure Rating	IP30	
Max Ambient Temperature	45°C	
Overall Dimensions	210mm wide, 115mm high, 50mm deep	
Max. No. of programmable operations	200 which may be freely allocated throughout the 7 days	
Setting and Running Accuracy	+/- 1 min and +/- 1 min/month	
Mode of operation	Provides either a continuous or interrupted pulse (½ second 'ON' followed by ½ second 'OFF') for a duration of between 1-15 seconds at each programmed event. The unit leaves the factory set for a single pulse of 5 seconds duration. This can be reset if required (see paragraphs 10 and 11 overleaf)	Provides either continuous or interrupted pulse (½ second 'ON' followed by ½ second 'OFF') on each channel for a duration of 1-15 seconds at each programmed event. The unit leaves the factory with both channels set for a single pulse of 5 seconds duration. Either or both of these can be reset independently of each other to give differing outputs (see paragraphs 10 and 11 overleaf).
Control Pollution Situation	Degree 2	
Software Classification	Class A	
Rated Impulse Voltage	2.5kV	
Ball Pressure Test	75°C	

MODEL 841



MODEL 842



This product complies with the following EC Directives:
Electro-Magnetic Compatibility Directive.
 (EMC) (89\336\EEC), (92\31\EEC)
Low Voltage Directive.
 (LVD) (73\23\EEC), (93\68\EEC)



Danfoss Randall can accept no responsibility for possible errors in catalogues, brochures and other printed material. Danfoss Randall reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without subsequent changes being necessary in specifications already agreed.

Danfoss Randall Ltd,
 Ampthill Road,
 Bedford MK42 9ER
 Tel: (01234) 364621 Fax: (01234) 219705
 Email: danfossrandall@danfoss.com
 Website: www.danfoss-randall.co.uk

